



Sieć Badawcza Łukasiewicz
WARSZAWSKI INSTYTUT TECHNOLOGICZNY
Certification Department
 01-796 Warszawa, ul. Duchnicka 3

e-mail: certyfikacja.duchnicka@wit.lukasiewicz.gov.pl
www.wit.lukasiewicz.gov.pl



CERTIFICATE OF CONFORMITY
No. P41/208/2025 (9288)
ENGLISH EDITION

Name and address of the certificate owner:

CIPIERRE SRL
Via Massimi 154, 00136, Rome, Italy

Name and address of the manufacturer:

CIPIERRE SRL
Via Massimi 154, 00136, Rome, Italy

Product name:

Mortise lock

Type (variants):

**90128/60/AB, 90128/70/AB, 90228/60/AB,
 90237/70/AB**

Main features:

Class of protection: : - 7 - PN-EN 12209:2016-04

1	2	3	4	5	6	7	8
Category of use	No of test cycles/ durability	Door mass	Fire resistance	Safety in use	Corrosion resistance	Protection requirements	Key identification
3	B	4	0	0	0	7	0

The product fulfills requirements of:

PN-EN 12209:2016-04

Date of expiration: **29 November, 2028**

This certificate is valid from **30 November, 2025** until **29 November, 2028** under assumption that the technical specification is valid, item fulfills its requirements and there were no major changes in: product type, system, conditions and the place of the production.

Certification of conformity Type „3” acc. to PN-EN ISO/IEC 17067:2014-01.

Voluntary Certificate of conformity issued acc. to the program PC-03

Process identification number: 109/W/2025

MANAGER
CERTIFICATION DEPARTMENT

Marek ZIĘTALA M.Sc. Eng.

DEPUTY DIRECTOR for QUALITY
and COMMERCIALIZATION

Grzegorz GUDZBELER Ph.D.

Certificate can be published only by Certificate Owner without comments, abbreviations and changes.
Warsaw, 25 November, 2025.